


NOTES:

1. METER SOCKET MAY BE CONNECTED TO AN EXTERNAL GROUND ROD IF REQUIRED BY LOCAL INSPECTION AUTHORITY.
2. CUSTOMER TO SUPPLY AND INSTALL SERVICE LATERAL METER RISER CONDUIT AS SHOWN ABOVE. (BOND ALL JOINTS)
3. CONDUIT STRAP—LOCATE HEAVY GAUGE 2 HOLE GALVANIZED STRAP JUST BELOW BEND COUPLING. ANCHOR SECURELY INTO MASONRY USING 3/8" MIN. DIAMETER FASTENERS.
- ▶ 4. CUSTOMER SHALL PROVIDE GROUND MOVEMENT PROTECTION PER NEC 300.5(J) TO PREVENT DAMAGE DUE TO SETTLEMENT OR FROST HEAVES. THE COMPANY RECOMMENDS THE USE OF A SLIP JOINT CONDUIT PRODUCT SUCH AS RIZZCON SAFETY SLIP.

<p>SUSSEX RURAL ELECTRIC COOPERATIVE</p>  <p>64 County Route 639 Sussex, New Jersey 07461</p>	<p>SINGLE-PHASE UNDERGROUND SERVICE IN CONDUIT</p>	<p>Service Guide</p>	<p>Rev.</p>
		<p>EXHIBIT 5B</p>	<p>1</p> <p>Date</p> <p>6/07</p>