



NOTES:

1. SUPPORT POST – USE ANY OF THE FOLLOWING:
 2-3" MIN. STEEL PIPE CAPPED AND CEMENTED IN GROUND
 2-3" MIN. GALV. STEEL I-BEAM (3/8"-1/2" THICK) CEMENTED IN GROUND
 2-3" MIN. CHANNEL IRON CEMENTED IN GROUND
2. MOUNTING HARDWARE – TWO 12 GAUGE 1-5/8" X 1-5/8" CONTINUOUS SLOT HOT DIPPED GALVANIZED CHANNEL (e.g., UNISTRUT) COMPLETE WITH 1-1/4" X 5/16" DIA. 13 THD SPRING NUT (2 PER CHANNEL), 5/16" HEX NUT, AND LOCK WASHER SECURELY MOUNTED TO SUPPORT POSTS.
3. SUPPLY SIDE CONDUIT SHALL BE RIGID GALVANIZED OR IMC STEEL, OR SCHEDULE 80 PVC (ELECTRICAL GRADE)
4. METER SOCKET(S) MAY BE CONNECTED TO AN EXTERNAL GROUND ROD IF REQUIRED BY LOCAL INSPECTION AUTHORITIES.
5. FOR CUSTOMER/COMPANY RESPONSIBILITIES SEE COMPANY SPECIFIC SERVICE GUIDE EXHIBIT 19.

SUSSEX RURAL ELECTRIC COOPERATIVE  64 County Route 639 Sussex, New Jersey 07461	UNDERGROUND SERVICE CENTRAL DISTRIBUTION INSTALLATION	Service Guide	Rev. 1
		EXHIBIT 10	Date 6/07