


**NOTES:**

1. BOND AND GROUND ACCORDING TO NEC 250.
2. METER SOCKET MAY BE CONNECTED TO AN EXTERNAL GROUND ROD, IF REQUIRED BY LOCAL INSPECTION AUTHORITIES.
3. WHERE METER IS EXPOSED TO VEHICLE TRAFFIC, CUSTOMER INSTALL PROTECTIVE BUMPER POSTS 36" FROM METER. POST SHALL BE 6" RIGID GALVANIZED STEEL PIPE FILLED WITH CONCRETE AND PAINTED BRIGHT YELLOW.
4. CT CABINET TO BE INSTALLED ON EXTERIOR BUILDING WALL.  
(FOR INDOOR CT CABINET INSTALLATIONS CONTACT SUSSEX REC)
5. FOR CUSTOMER/ COMPANY RESPONSIBILITIES SEE COMPANY SPECIFIC SERVICE GUIDE EXHIBIT 19.
6. NO CONDUIT SHALL ENTER TOP OF CT CABINET.

SUSSEX RURAL ELECTRIC COOPERATIVE  64 County Route 639 Sussex, New Jersey 07461	<b>METERING INSTALLATION OUTDOOR CT CABINET</b>	<b>Service Guide</b>	Rev.
		<b>EXHIBIT 13</b>	1
			Date 6/07