


NOTES:

1. THE COMPANY WILL DESIGNATE THE QUARTER OF THE POLE FOR INSTALLATION OF THE SERVICE RISER, BASED UPON TRAFFIC FLOW AND LOCATION OF TELEPHONE OR CABLE COMPANY ATTACHMENTS.
2. WHEN THE CONDUIT RISER IS 3" IN DIAMETER IT SHALL BE STRAPPED DIRECTLY TO THE POLE; RISER CONDUITS GREATER THAN 3" IN DIAMETER SHALL BE SET-OFF 5-1/5" FROM POLE ON COMPANY SUPPLIED STANDOFF BRACKETS.
3. CUSTOMER TO INSTALL NEC APPROVED RISER CONDUIT 10 FEET UP POLE AND SHALL PROVIDE PULL ROPE.
3. FOR CUSTOMER/ COMPANY RESPONSIBILITIES SEE COMPANY SPECIFIC SERVICE GUIDE EXHIBIT 19.

 <p>SUSSEX RURAL ELECTRIC COOPERATIVE 64 County Route 639 Sussex, New Jersey 07461</p>	<p>DIRECT ATTACHMENT OF CUSTOMER UNDERGROUND SECONDARY SERVICE LATERALS IN CONDUIT</p>	<p>Service Guide</p>	<p>Rev.</p>
		<p>EXHIBIT 6</p>	<p>1</p>
			<p>Date</p>